

QUESTIONS AND ANSWERS

No.	Question	Response
1	<p>I just went through the document and there seems to be no mention of the power supply needed for the facility in amps.</p> <p>Please can we get confirmation on this</p>	<p>The site should have power availability from 800 kVA, with the ability to upgrade in line with equipment commissioning. Considering existing equipment plans, the power requirement is not expected beyond 3 MVA.</p> <p>It should be noted that the successful bidder must permit the client to carry out reconfiguration, repair and upgrade (which is not part of this bid) of the building(s) building after signing a lease agreement, especially as the space needs to be customized or updated to suit the GPW's needs. (Refer to page 44/70 of the Tender document).</p>
2		

